

DAFTAR PUSTAKA


- Agrimansyah, M., Amin, N., & Sarjan, M. (2021). Perancangan Instalasi Listrik Pada Gedung Markas Komando Direktorat Kepolisian Perairan Dan Udara Kepolisian Daerah Sulawesi Tengah Di Desa Wani. *Foristek*, 10(2). <https://doi.org/10.54757/fs.v10i2.39>
- ASHRAE. 1997. ASHRAE-HANDBOOK-1997 Fundamental. Atlanta: American Society of Heating, Refrigeration and Air Conditioning Engineers.
- Bachtiar, M. I., & Riyadi, K. (2021). Studi Kabel Penghantar pada Instalasi Listrik Gedung Pertemuan Unhas Berstandarisai PUIL 2011. *Jurnal Teknologi Elekterika*, 5(2), 70. <https://doi.org/10.31963/elekterika.v5i2.3031>
- Badan Meteorologi Klimatologi dan Geofisika. (2024). *Data iklim harian kota Makassar periode Juni 2024*. <https://www.bmkg.go.id/dataiklim/makassar-Juni2024> (diakses pada 13 Agustus 2024)
- Badan Standarisasi Nasional. (2001). Tata Cara Perancangan Sistem Ventilasi dan Pengkondisian Udara pada Bangunan Gedung. *Sni 03-6572-2001*, 1–55.
- Chandra, M. D. (2021). *Perangkat Hubung Bagi Tegangan Rendah (PHB-TR) pada PT. Adra Gemilang*. 5(1), 1–52.
- Edward G. Pita. (2013). Air Conditioning Principles and System. In *Journal of Chemical Information and Modeling* (Vol. 53, Issue 9).
- Euis Soliha. (2008). ANALISIS INDUSTRI RITEL DI INDONESIA Oleh: Euis Soliha Fakultas Ekonomi Universitas Stikubank Semarang. *Jurnal Bisnis Dan Ekonomi (JBE)*, 15(2), 128–143.
- Fuady, F. (2017). *Evaluasi Beban Pendingin Dan Peluang Penghematan Di Lantai IV Dan VI UNIVERSITAS XYZ*.
- Hartoyo. (2009). Teknik Pendingin dan Tata Udara pada AC Window dan AC Split. *Universitas Negeri Yogyakarta*, 1–33.
- Irhami, M. R. (2020). *Studi Analisis Perencanaan Instalasi Kelistrikan Yang*

Efisien Di Gedung Fakultas Teknik Uma. 6.

- Ismansyah. (2009). Universitas Indonesia perancangan instalasi listrik pada rumah dengan daya listrik besar skripsi. *Universitas Indonesia, 1*, 90.
- Mulyani, D., & Hartono, D. (2018). Pengaruh Efisiensi Energi Listrik pada Sektor Industri dan Komersial terhadap Permintaan Listrik di Indonesia. *Jurnal Ekonomi Kuantitatif Terapan*, 1. <https://doi.org/10.24843/jekt.2018.v11.i01.p01>
- Persyaratan Umum Instalasi Listrik. (2011). Persyaratan Umum Instalasi Listrik 2011 (PUIL 2011). *DirJen Ketenagalistrikan, 2011(PUIL)*, 1–133.
- Prok, A. D., Tumaliang, H., & Pakiding, M. (2018). Penataan Dan Pengembangan Instalasi Listrik Fakultas Teknik UNSRAT 2017. *Jurnal Teknik Elektro Dan Komputer*, 7(3), 207–218. <https://ejournal.unsrat.ac.id/index.php/elekdankom/article/view/20767>
- Purwanto, E., & Ridhuan, K. (2014). Pengaruh Jenis Refrigerant Dan Beban Pendinginan Terhadap Kemampuan Kerja Mesin Pendingin. *Turbo : Jurnal Program Studi Teknik Mesin*, 3(1), 11–16. <https://doi.org/10.24127/trb.v3i1.19>
- Rivai, M. B. (2022). Perancangan Instalasi Penerangan Pada Gedung Bertingkat X. *Power Elektronik : Jurnal Orang Elektro*, 11(2), 184. <https://doi.org/10.30591/polektro.v12i1.3650>
- Sahnur Nasution, E., Pasaribu, I., Ramadhan dan, D., & Roza, I. (2023). Perencanaan Instalasi Listrik Di Pt. Arga Citra Kharisma Pada Down Sizing Lottemart. *Semnastek Iusu*, VI(1), 147–152.
- Sutarsa, I. W., Putra, A. A. K. W., & Widianegara, I. W. (2020). Pengaruh Modifikasi AC Chiller Yang Menggunakan Heat Recovery Terhadap Perbandingan Coefficient of Performance (COP) ABSTRAK ISSN 2655 4887 (Print), ISSN 2655 1624 (Online) ISSN 2655 4887 (Print), ISSN 2655 1624 (Online). *Indonesian Journal of Laboratory*, 2(2), 16–24.

Wahyu Pramon, E., Karnoto, K., & Nurhayati, T. (2018). Evaluasi Instalasi Listrik Pada Gedung Multi Centre of Excellent (Mce) Rumah Sakit Islam Sultan Agung Semarang. *ELEKTRIKA*, 9(1), 17.
<https://doi.org/10.26623/elektrika.v9i1.1110>

LAMPIRAN



MAIN DISTRIBUTION PANEL (MDP-1)						
3 PHASE, 4 WIRE, 220/380V, 50Hz						
CCT No	FUNCTION	POWER (KVA)	CONNECTED LOAD (AMPS.)			NOTE
			FASA R	FASA S	FASA T	
1	PP - RD1	6.00	9.00	9.00	9.00	
2	PP - RD2	7.00	12.00	9.00	9.00	
3	PP - RD3	3.30	6.00	6.00	3.00	
4	LP - CL1	10.00	17.00	15.80	15.00	
5	LP - CL2	7.50	12.40	10.6	11.2	
6	LP - FV	18.00	26.00	38.00	22.00	
7	LP - WH-1	5.60	7.00	9.00	9.40	
8	LP - WH-2	3.00	7.00	4.30	3.00	
9	LP - SO-1	8.60	11.00	12.70	17.00	
10	LP - SO-2	10.00	16.00	13.00	16.45	
11	PP - VAC-1	72.00	113.00	111.00	104.00	
12	PP - VAC-2	73.00	116.00	106.00	123.00	
13	PP - SA-1	43.00	70.00	58.30	68.00	
14	PP - SA-2	35.00	59.30	56.10	46.70	
15	PP - SA-3	45.00	68.00	74.00	66.00	
16	PP - SA-4	30.00	50.00	41.00	43.00	
17	SPARE					
18	SPARE					
19	SPARE					
20	SPARE					
TOTAL AMP			600.00	574.00	566.00	
TOTAL KVA			377.00			
D.F. 85%, kVA			320.00			

Lampiran 2





DIAGRAM PANEL ROLLING DOOR 3 PHASE 4 WIRE, 220V/380V, 50Hz					
NO CCT	FUNCTION	LOAD CIRCUIT (AMPS.)			NOTE
		FASA R	FASA S	FASA T	
1	RD-1 (500 WATT 1ø)	3.00			
2	RD-2 (500 WATT 1ø)		3.00		
3	RD-3 (500 WATT 1ø)			3.00	
4	RD-4 (500 WATT 1ø)	3.00			
5	RD-5 (500 WATT 1ø)		3.00		
6	RD-6 (500 WATT 1ø)			3.00	
7	RD-7 (500 WATT 1ø)	3.00			
8	RD-8 (500 WATT 1ø)		3.00		
9	RD-9 (500 WATT 1ø)			3.00	
10	SPARE				
11					
12					
TOTAL AMP :		9.00	9.00	9.00	
TOTAL KVA :		6.00			

DIAGRAM POWER PANEL - ROLLING DOOR (PP-RD-1)

Lampiran 3



PP-RD-3
(ROLLING DOOR CASHIER LINE 1ST FLOOR)

CASHIER LINE - GROUND FLOOR

NOT TO SCALE

1


DIAGRAM PANEL ROLLING DOOR LOADING DOCK 3 PHASE 4 WIRE, 220V/380V, 50Hz					
NO CCT	FUNCTION	LOAD CIRCUIT (AMPS.)			NOTE
		FASA R	FASA S	FASA T	
1	RD-1 (500 WATT 1ø)	3.00			LOADING DOCK AREA
2	RD-2 (500 WATT 1ø)		3.00		
3	RD-3 (500 WATT 1ø)			3.00	
4	RD-4 (500 WATT 1ø)	3.00			
5	RD-5 (500 WATT 1ø)		3.00		
6	RD-6 (500 WATT 1ø)			3.00	
7	RD-7 (500 WATT 1ø)	3.00			
8	RD-8 (500 WATT 1ø)		3.00		
9	RD-9 (500 WATT 1ø)			3.00	
10	RD-10 (500 WATT 1ø)	3.00			
11	SPARE				
12					
13					
TOTAL AMP :		12.00	9.00	9.00	
TOTAL kVA :		7.00			

DIAGRAM POWER PANEL - ROLLING DOOR (PP-RD-2)
LOADING DOCK - GROUND FLOOR

NOT TO SCALE

2

Lampiran 4



LOADING DOOR - GROUND FLOOR

NOT TO SCALE

2


DIAGRAM PANEL ROLLING DOOR 3 PHASE 4 WIRE, 220V/380V, 50Hz					
NO CCT	FUNCTION	LOAD CIRCUIT (AMPS.)			NOTE
		FASA R	FASA S	FASA T	
1	RD-1 (500 WATT 1Ø)	3.00			
2	RD-2 (500 WATT 1Ø)		3.00		
3	RD-3 (500 WATT 1Ø)			3.00	
4	RD-4 (500 WATT 1Ø)	3.00			
5	RD-5 (500 WATT 1Ø)		3.00		
6	SPARE				
7					
8					
TOTAL AMP :		6.00	6.00	3.00	
TOTAL KVA :		3.30			

DIAGRAM POWER PANEL - ROLLING DOOR (PP-RD-3)
CASHIER LINE 1st FLOOR


NOT TO SCALE

3


Lampiran 5



Lampiran 6



Lampiran 7




LIGHTING PANEL FRUIT & VEGETABLE (LP-FV) 3 FASA 4 WIRE, 220/380V, 50Hz												
NO CCT	FUNCTION	LOCATION		CONNECTED LOAD (AMP)			LIGHTING, RECEPTACLE & SWITCH					NOTE
				FASA R	FASA S	FASA T	 TL5.2x28W	 CDM-T.70W	 16A	 16A		
1	LIGHTING	FRUIT & VEGETABLE		8.00			25					
2					8.30		26					
3						8.00	25					
4				8.00			25					
5					8.30		26					
6						4.00		10				
7				4.80				12				
8					4.80			12				
9						4.80		12				
10				4.80				12				
11					4.80			12				
12	↓					4.80		12				
13	SPARE											
14			↓									
15												
16	↓											
TOTAL AMP.				26.00	33.00	22.00	127	82	-	-		
TOTAL KVA				18.00								

DIAGRAM LIGHTING PANEL
LP-FV (FRUIT & VEGETABLE)


NOT TO SCALE




Lampiran 8



Lampiran 9





Lampiran 10



CCT NO	FUNCTION	CONNECTED LOAD (AMPS.)			LIGHTING, RECEPTACLE & SWITCHES											NOTE	
		PHASE R	PHASE S	PHASE T													
1	LIGHTING	1.30			2	2	1							2	1		
2	↓		1.60		3	4		1						4	1		
3	↓			2.50	16									1	1		
4	↓	1.60			5										2		
5	↓			1.75		11								1			
6	RECEPTACLE		2.40									3					
7	↓			2.40								3					
8	↓	3.20										4					
9	↓		2.40									3					
10	RECEPTACLE 3 PHASE	4.00	4.00	4.00									1				
11	EMERG & EXIT		2.10					6	1								
12	EMERG & EXIT			2.10				6	2								
13	WATER HEATER	3.60										1					
14	↓		3.60									1					
15	↓	3.60										1					
16	WATER PURIFIER		3.60									1					
17	SPARE																
18	↓																
19	↓																
TOTAL AMP.		17.30	16.10	16.40	26	17	1	1	12	3	17		1	8	5		
TOTAL KVA		11.00															

Lampiran 11





VAC POWER PANEL PP-VAC-1								
3 PHASE, 4 WIRE, 220/380V, 50Hz								
CCT No	FUNCTION	POWER (kW)	CONNECTED LOAD (AMPS.)			RECEPTACLE		NOTE
			FASA R	FASA S	FASA T	CROSS-T 	 16A	
1	IU-GF-01	1.80 (#1)	10.00			1		
2	IU-GF-02	2.50 (#1)		14.00		1		
3	IU-GF-03	2.50 (#1)			14.00	1		
4	IU-GF-04	2.50 (#1)	14.00			1		
5	IU-GF-05	2.50 (#1)		14.00		1		
6	IU-GF-06	2.50 (#1)		14.00		1		
7	IU-GF-07	2.50 (#1)			14.00	1		
8	IU-GF-08	1.80 (#1)	10.00			1		
9	IU-GF-09	1.20 (#1)		7.00		1		
10	IU-GF-10	1.40 (#1)			8.00	1		
11	IU-GF-11	1.40 (#1)	8.00			1		
12	IU-GF-12	1.80 (#1)			10.00	1		
13	IU-GF-12 ¹³	1.80 (#1)		10.00				
14	IU-GF-12 ¹⁴	2.10 (#1)	12.00					
15	IU-GF-12 ¹⁵	3.90 (#1)			22.00			
16	FAF-GF-1 (SPG LOCKERS ROOM-1)	5.50 (#3)	10.00	10.00	10.00		1	
17	FAF-GF-2 (SPG LOCKERS ROOM-2)	5.50 (#3)	10.00	10.00	10.00		1	
18	KEF-GF-1 (DEUCA)	7.50 (#3)	14.00	14.00	14.00		1	
19	EAF-GF-2 (LOADING DOCK)	4.00 (#3)	8.00	8.00	8.00		1	
20	SPARE							
21								
22								
TOTAL AMP			96.00	101.00	120.00			
TOTAL IWA			70.00					
						12	4	

**DIAGRAM POWER PANEL (PP-VAC-1)
STORE OFFICE - GROUND FLOOR**

NOT TO SCALE



Lampiran 13





DIAGRAM POWER PANEL (PP-VAC-2)
STORE OFFICE - 1st FLOOR

NOT TO SCALE



Lampiran 14




NO CCT	FUNCTION	LOCATION	CONNECTED LOAD (AMP)			LIGHTING, RECEPTACLE & SWITCH						NOTE
			FASA R	FASA S	FASA T	 15.2x228W	 16A	 16A	 HL 2X10W	 FL 1X10W		
1	LIGHTING	SALES AREA ZONE 1A	11.00			35						
2	↓			10.00		32						
3				10.50		33						
4				10.80		34						
5	SPARE											
6												
7	↓											
8	LIGHTING				2.20	7						
9	↓		2.90			9						
10				2.20		7						
11					2.60	8						
12	SPARE											
13												
14	↓											
15	RECEPTACLE			4.60			2	2				
16					4.60		2	2				
17	↓		4.60				2	2				
18	SPARE											
19												
20	↓											
TOTAL AMP.			29.00	17.00	16.00	165	6	6				
SUB TOTAL KVA			14.00									

NO CCT	FUNCTION	LOCATION	CONNECTED LOAD (AMP)			LIGHTING, RECEPTACLE & SWITCH						NOTE
			FASA R	FASA S	FASA T	 TL5.2x28W	 HL 2X10W	 FL 1X10W	 16A	 16A	 16A	
1	LIGHTING	SALES AREA ZONE 1B	10.00			32						
2	↓			10.80		34						
3					10.00	32						
4	↓				11.00	35						
5	SPARE											
6												
7	↓											
8	RECEPTACLE		4.60						2		2	
9	↓			3.40					3			
10	EMERG & EXIT			2.30			6	5		6		
11	↓											
12	↓											
TOTAL AMP.			15.00	16.30	21.00	133	6	5	5	6	2	
SUB TOTAL KVA			11.00									


LIGHTING PANEL SALES AREA 3 FASA 4 WIRE, 220/380V, 50Hz											
NO CCT	FUNCTION	LOCATION	CONNECTED LOAD (AMP)			LIGHTING, RECEPTACLE & SWITCH					NOTE
			FASA R	FASA S	FASA T	 TL5 2x28W	 15A	 15A			
1	LIGHTING	SALES AREA ZONE 1C	8.60			27					
2				8.00		25					
3					8.60	27					
4			8.60			27					
5				8.00		25					
6	↓				8.60	27					
7	SPARE										
8	↓										
9	RECEPTACLE				4.60		4				
10			4.60				2	2			
11				5.60			1	4			
12					4.60		2	2			
13			4.60				3	1			
14		↓		3.40			1	2			
15					4.60		3	1			
16	SPARE										
17	↓										
TOTAL AMP.			26.00	25.00	31.00	158	16	12			
SUB TOTAL KVA			18.00								
TOTAL KVA			43.00								

Lampiran 15

PP-SA-2 (SALES AREA - GROUND FLOOR)



LIGHTING PANEL SALES AREA 3 FASA 4 WIRE, 220/380V, 50Hz													
NO CCT	FUNCTION	LOCATION	CONNECTED LOAD (AMP)			LIGHTING, RECEPTACLE & SWITCH							NOTE
			FASA R	FASA S	FASA T	 15A 2x20W	 15A	 15A					
1	LIGHTING	SALES AREA ZONE 2A	8.50			27							
2				8.50		27							
3					7.50	24							
4			8.50			27							
5	↓			8.50		27							
6	SPARE												
7													
8	↓												
9	RECEPTACLE		4.60				2	2					
10				4.60			2	2					
11					4.60		2	2					
12	↓	↓	4.60				2	2					
13	SPARE												
14	↓												
TOTAL AMP.			26.00	22.00	12.00	132	8	8					
SUB TOTAL KVA			13.00										




LIGHTING PANEL SALES AREA 3 FASA 4 WIRE, 220/380V, 50Hz												
NO CCT	FUNCTION	LOCATION	CONNECTED LOAD (AMP)			LIGHTING, RECEPTACLE & SWITCH						NOTE
			FASA R	FASA S	FASA T	 ILS 2x2W	 DL 2x2W	 16A	 16A			
1	LIGHTING	SALES AREA ZONE 2B	5.40			17						
2				6.00		19						
3					6.00	19						
4			5.40			17						
5	↓			6.00		19						
6	SPARE				6.00	19						
7												
8	↓											
9	RECEPTACLE		3.40					2	1			
10	↓			4.50				2	2			
11		↓			4.50			2	2			
12	SPARE											
13												
14	↓											
TOTAL AMP.			14.20	16.50	16.50							
SUB TOTAL KVA			10.00			110		6	5			

LIGHTING PANEL SALES AREA 3 FASA 4 WIRE, 220/380V, 50Hz												
NO CCT	FUNCTION	LOCATION	CONNECTED LOAD (AMP)			LIGHTING, RECEPTACLE & SWITCH						NOTE
			FASA R	FASA S	FASA T	 TL5 2x28W	 HL 2X10W	 FL 1X10W	 15A	 15A DM	 15A	
1	LIGHTING	SALES AREA ZONE 2C	5.70			18						
2				6.40		20						
3					7.00	22						
4			6.40			20						
5				6.70		21						
6	↓				5.70	21						
7	SPARE											
8	SPARE											
9	RECEPTACLE		4.50						2		2	
10				4.50					2		2	
11	↓	↓			4.50				3		1	
12	EMERG & EXT		2.50				7	2		7		
13	SPARE											
14	↓											
TOTAL AMP.			19.10	17.60	18.20	122	7	2	7	7	5	
SUB TOTAL KVA			12.00									
TOTAL KVA			35.00									


Lampiran 16

PP-SA-3 (SALES AREA - 1st FLOOR)

220V/380V
50Hz




LIGHTING PANEL SALES AREA 3 FASA 4 WIRE, 220/380V, 50Hz												
NO CCT	FUNCTION	LOCATION	CONNECTED LOAD (AMP)			LIGHTING, RECEPTACLE & SWITCH						NOTE
			FASA R	FASA S	FASA T	 TL5 2x28W	 HL 2x10W	 FL 1x10W	 16A	 16A	 16A	
1	LIGHTING	SALES AREA ZONE 3A	5.00			16						
2				5.00		15						
3					5.00	15						
4			5.00			15						
5				5.00		14						
6					5.00	15						
7			5.00			15						
8				5.00		15						
9					5.00	15						
10	EMERG & EXIT		2.30				6	5		6		
11												
12	LIGHTING			2.00		6						
13					1.50	4						
14			1.50			4						
15				1.50		4						
16					1.50	4						
17			1.50			9						
18	SPARE											
19												
20												
21	RECEPTACLE			4.00					4			
22					4.00				2		2	
23			4.00						2	2	2	
24				4.00					2		2	
25					2.00						2	
26	SPARE											
27												
28												
TOTAL AMP.			37.00	42.00	39.30	172	6	5	10	6	8	
SUB TOTAL KVA			26.00									




LIGHTING PANEL SALES AREA 3 FASA 4 WIRE, 220/380V, 50Hz											
NO CCT	FUNCTION	LOCATION	CONNECTED LOAD (AMP)			LIGHTING, RECEPTACLE & SWITCH					NOTE
			FASA R	FASA S	FASA T	 TL5 2x28W	 DL 2x28W	 16A	 16A		
1	LIGHTING	SALES AREA ZONE 3B	7.00			21					
2				7.00		21					
3					5.00	19					
4			7.00			21					
5				7.00		21					
6					7.00	21					
7			5.00			19					
8				5.00			8				
9	SPARE										
10	RECEPTACLE				4.00			3	1		
11			4.00					1	3		
12					3.00			1	2		
13	SPARE										
14											
15											
TOTAL AMP.			15.00	16.00	13.00	143	8	5	6		
SUB TOTAL KVA			10.00								

LIGHTING PANEL SALES AREA 3 FASA 4 WIRE, 220/380V, 50Hz												
NO CCT	FUNCTION	LOCATION	CONNECTED LOAD (AMP)			LIGHTING, RECEPTACLE & SWITCH						NOTE
			FASA R	FASA S	FASA T	TL5 2x28W	16A	16A				
1	LIGHTING	SALES AREA ZONE 3C	8.50			26						
2				8.50		26						
3					8.50	25						
4			8.50			26						
5	↓			4.00		13						
6	SPARE											
7												
8	↓											
9	RECEPTACLE				4.00		2	2				
10					4.00		2	2				
11	↓	↓		4.00			2	2				
12	SPARE											
13	↓											
14	↓											
TOTAL AMP.			16.00	16.00	16.00	116	6	6				
SUB TOTAL KVA			9.00									
TOTAL KVA			45.00									




LIGHTING PANEL SALES AREA 3 FASA 4 WIRE, 220/380V, 50Hz												
NO CCT	FUNCTION	LOCATION	CONNECTED LOAD (AMP)			LIGHTING, RECEPTACLE & SWITCH						NOTE
			FASA R	FASA S	FASA T	 TL5 2x28W	 HL 2X10W	 FL 1X10W	 15A	 EM 15A	 15A	
1	LIGHTING	SALES AREA ZONE 4A	5.00			16						
2				5.00		16						
3					5.00	14						
4			5.00			16						
5				5.00		16						
6					5.00	14						
7			5.00			16						
8				5.00		16						
9	SPARE											
10												
11												
12	RECEPTACLE			4.00					2		2	
13					4.00				2		2	
14					4.00				2		2	
15	EMERG & EXIT			3.20			9	2		9		
16	SPARE											
17												
TOTAL AMP.			12.00	11.00	13.00	124	9	2	6	9	6	
SUB TOTAL KVA			8.00									

[illegible]

LIGHTING PANEL SALES AREA 3 FASA 4 WIRE, 220/380V, 50Hz											
NO CCT	FUNCTION	LOCATION	CONNECTED LOAD (AMP)			LIGHTING, RECEPTACLE & SWITCH					NOTE
			FASA R	FASA S	FASA T	 1L5.2x28W	 16A	 16A			
1	LIGHTING	SALES AREA ZONE 4C	8.00			25					
2				8.00		25					
3				8.00		24					
4				8.00		28					
5		SPARE									
6											
7											
8		RECEPTACLE		4.00			2	2			
9					4.00			4			
10			4.00				2	2			
11				2.00			2				
12		SPARE									
13											
14											
	TOTAL AMP.		21.00	15.00	12.00						
	SUB TOTAL KVA		11.00			101	4.	10			
	TOTAL KVA		30.00								


Lampiran 18




MAIN DISTRIBUTION PANEL (MDP-2)						
3 PHASE, 4 WIRE, 220/380V, 50Hz						
CCT No	FUNCTION	POWER (KVA)	CONNECTED LOAD (AMPS.)			NOTE
			FASA R	FASA S	FASA T	
1	PP - DELICA	52.00	78.00	87.00	88.00	
2	SDP - UPS	31.00	38.00	40.00	32.50	
3	PP - LIFT-1	25.00	37.80	37.80	37.80	
4	PP - LIFT-2	25.00	28.30	28.30	28.30	
5	PP - TRAVOLATOR-1	9.50	14.40	14.40	14.40	
6	PP - TRAVOLATOR-2	9.50	14.40	14.40	14.40	
7	LP - FP	5.00	8.70	8.40	6.80	
8	PP - BUTCHERY (PP-BEEF, PP-POULTRY, PP-FISH)	42.00	51.00	48.50	49.00	
9	PP - BAKERY	31.00	44.50	42.00	52.00	
10	PP - COMPRESSOR	250.00	378.00	378.00	378.00	
11	PP - SUMP PUMP	3.00	4.20	4.20	4.20	
12	LP-SB	3.00	4.40	3.40	2.50	SEMI BASEMENT FLOOR
13	SPARE					
14	SPARE					
15	SPARE					
TOTAL AMP			707.70	712.70	715.20	
TOTAL KVA			472.00			
D.F. 85%, KVA			401.00			

MAIN DISTRIBUTION PANEL (MDP-2)
NOT TO SCALE


2




Lampiran 20



Lampiran 21



Lampiran 22




[illegible]


PP-BAKERY (BKR)													
3 FASA 4 WIRE, 220V/380V, 50Hz													
NO CCT	FUNCTION	POWER KW (ø)	CONNECTED LOAD (AMPS.)			WIRING DEVICES							NOTE
			FASA R	FASA S	FASA T	 15A	 32A	 50A					
1	OVEN 4 DECK	45,00 (3ø)	23,00	23,00	23,00								
2	PROOFER 32S	5.5 (3ø)	3.50	3.50	3.50			1					
3	ELECTRIC 2 HOT PLATE BURNERS	5.2 (3ø)	3.00	3.00	3.00			1					
4	MIXER SM 401	7.5 (3ø)	5,00	5,00	5,00		1						
5	MIXER	1.50 (1ø)	7,00										
6	UPRIGHT CHILLER	1.25 (1ø)		6.00		1							
7	BREAD SLICER	0.2 (1ø)			1.00	1							
8	KNIFE STERILIZER	0.1 (1ø)	1.00			1							
9	HAND DRYER	1 (1ø)		1,00									
10	FOOD PROCESSOR	1 (1ø)			1,00	1							
11	MIXER SM 101	1 (1ø)	1.50			1							
12	INSECT KILLER	0.50 (1ø)		1.00									
13	RECEPTACLE	1,50 (1ø)			4.00	4							
14	WRAPPING MACHINE	0,50 (1ø)	1.00			1							
15	WATER HEATER	3,00 (1ø)			12.00	1							
16	SPARE												
17													
18													
19													
20													
TOTAL AMP.			44.50	42.00	52.00	11	1	2					
TOTAL KVA			30.00										

PP-DELICA
3 FASA 4 WIDE 220V/200V 50W

Lampiran 24



Lampiran 25



Lampiran 26

Tabel 7.3-5a KHA terus menerus untuk kabel tanah inti tunggal, berkonduktor tembaga, berinsulasi dan berselubung PVC, dipasang pada sistem a.s. dengan voltase kerja maksimum 1,8 kV; serta untuk kabel tanah 2-inti, 3-inti dan 4-inti berkonduktor tembaga, berinsulasi dan berselubung PVC yang dipasang pada sistem a.b. trifase dengan voltase pengenal 0,6/1 kV (1,2 kV), pada suhu ambien 30 °C.

Jenis kabel	Luas penampang mm ²	KHA terus menerus					
		Inti tunggal		2-inti		3-inti dan 4-inti	
		di tanah	di udara	di tanah	di udara	di tanah	di udara
1	2	A	A	A	A	A	A
	1,5	40	26	31	20	26	18,5
	2,5	54	35	41	27	34	25
	4	70	46	54	37	44	34
	6	90	58	68	48	56	43
NY Y	10	122	79	92	66	75	60
NY BY	16	160	105	121	89	98	80
NY FGB Y							
NY RGB Y	25	206	140	153	118	128	106
NY CY	35	249	174	187	145	157	131
NY CWY	50	296	212	222	176	185	159
NY SY							
NY CEY	70	365	269	272	224	228	202
NY SEY	95	438	331	328	271	275	244
NY HSY	120	499	386	375	314	313	282
NYKY							
NY KBY	150	561	442	419	361	353	324
NY KFGB Y	185	637	511	475	412	399	371
NY KRGB Y	240	743	612	550	484	464	436
	300	843	707	525	590	524	481
	400	986	859	605	710	600	560
	500	1125	1000	-	-	-	-

Lampiran 27

Tabel 7.3-18 Faktor koreksi untuk KHA kabel tanah yang dipasang di udara dengan suhu ambien lain dari 30 °C

Suhu ambien	25 °C	30 °C	35 °C	40 °C
1	2	3	4	5
Kabel dengan voltase pengenal 0,6/1 kV (1,2 kV)	1,06	1,00	0,94	0,87

Lampiran 28

SNI 0225:2011

Tabel 7.3-19 Faktor koreksi terhadap Tabel 7.3-5a sampai dengan 7.3-11b perhitungan KHA untuk kabel berinsulasi dan berselubung PVC multiinti dan inti tunggal (sistem arus searah) atau kabel berinsulasi XLPE, berpelindung bebat tembaga tanpa perisai baja dan berselubung PVC berinti tiga yang dipasang di udara pada sistem arus trifase

Penyusunan kabel	Jumlah penyangga kabel	Pemasangan tidak rapat [Jarak antara permukaan masing-masing kabel = diameter luar kabel (pemasangan mendatar, jarak dari dinding ke permukaan kabel 2 cm)]					Tata letak kabel	Pemasangan berhimpitan					Tata letak kabel
		Jumlah kabel						Jumlah ikatan kabel					
		1	2	3	6	9		1	2	3	6	9	
1	2	3	4	5	6	7	8	9	10	11	12	13	14
Kabel tanah di atas lantai		0,95	0,90	0,88	0,85	0,84		0,50	0,84	0,80	0,75	0,73	
Kabel tanah disusun pada penyangga kabel yang tertutup (sirkulasi udara terhindari)	1	0,95	0,90	0,88	0,85	0,84		0,95	0,84	0,80	0,75	0,73	
	2	0,95	0,85	0,83	0,81	0,80		0,95	0,80	0,76	0,71	0,69	
	3	0,88	0,83	0,81	0,79	0,78		0,95	0,78	0,74	0,70	0,68	
	6	0,88	0,81	0,79	0,77	0,76		0,95	0,76	0,72	0,68	0,66	
Kabel tanah disusun pada penyangga kabel terbuka	1	1,00	0,98	0,96	0,93	0,92		0,95	0,84	0,80	0,75	0,73	
	2	1,00	0,95	0,93	0,90	0,89		0,95	0,80	0,76	0,71	0,69	
	3	1,00	0,94	0,92	0,87	0,88		0,95	0,78	0,74	0,70	0,68	
	6	1,00	0,93	0,90	0,87	0,86		0,95	0,76	0,72	0,68	0,66	

Lampiran 30

126 CHAPTER 6

TABLE 6.2 COOLING LOAD TEMPERATURE DIFFERENCES (CLTD) FOR CALCULATING COOLING LOAD FROM SUNLIT WALLS, F

North Latitude Wall Facing	Solar Time, h																								Hr of Maxi- Mini- Maxi- Differ- ence CLTD CLTD CLTD CLTD				
	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	2400					
Group A Walls																													
N	14	14	14	13	13	13	12	12	11	11	10	10	10	10	10	10	11	11	12	12	13	13	14	14	2	10	14	4	
NE	19	19	19	18	17	17	16	15	15	15	15	15	15	16	16	17	18	18	18	19	19	20	20	20	22	15	20	5	
E	24	24	23	23	22	21	20	19	19	18	18	19	19	20	21	22	23	24	24	25	25	25	25	25	22	18	25	7	
SE	24	23	23	22	21	20	20	19	18	18	18	18	18	19	20	21	22	23	23	24	24	24	24	22	18	24	6		
S	20	20	19	19	18	18	17	16	16	15	14	14	14	14	14	15	16	17	18	19	19	20	20	20	23	14	20	6	
SW	25	25	25	24	24	23	22	21	20	19	19	18	17	17	17	18	19	20	22	23	24	25	25	24	17	25	8		
W	27	27	26	26	25	24	24	23	22	21	20	19	19	18	18	18	18	19	20	22	23	25	26	26	1	18	27	9	
NW	21	21	21	20	20	19	19	18	17	16	16	15	15	14	14	14	15	15	16	17	18	19	20	21	1	14	21	7	
Group B Walls																													
N	15	14	14	13	12	11	11	10	9	9	9	8	9	9	9	10	11	12	13	14	14	15	15	15	24	8	15	7	
NE	19	18	17	16	15	14	13	12	12	13	14	15	16	17	18	19	19	20	20	21	21	21	20	20	21	12	21	9	
E	23	22	21	20	18	17	16	15	15	15	17	19	21	22	24	25	26	26	27	27	27	26	26	25	24	20	15	27	12
SE	23	22	21	20	18	17	16	15	14	14	15	16	18	20	21	23	24	25	26	26	26	26	25	24	21	14	26	12	
S	21	20	19	18	17	15	14	13	12	11	11	11	11	12	14	15	17	19	20	21	22	22	22	21	23	11	22	11	
SW	27	26	25	24	22	21	19	18	16	15	14	13	13	14	15	17	20	22	25	27	28	28	28	28	24	13	28	15	
W	29	28	27	26	24	23	21	19	18	17	16	15	14	14	14	15	17	19	22	25	27	29	29	30	24	14	30	16	
NW	23	22	21	20	19	18	17	15	14	13	12	12	11	12	12	13	15	17	19	21	22	23	23	24	11	23	9		
Group C Walls																													
N	15	14	13	12	11	10	9	8	8	7	7	8	8	9	10	12	13	14	15	16	17	17	17	16	22	7	17	10	
NE	19	17	16	14	13	11	10	10	11	13	15	17	19	20	21	22	23	23	23	23	23	22	21	20	20	10	23	13	
E	22	21	19	17	15	14	12	12	14	16	19	22	25	27	29	30	30	30	30	29	28	27	26	24	18	12	30	18	
SE	22	21	19	17	15	14	12	12	12	13	16	19	22	24	26	28	29	29	29	29	28	27	26	24	19	12	29	17	
S	21	19	18	16	15	13	12	10	9	9	9	10	11	14	17	20	22	24	25	26	25	25	24	22	20	9	26	17	
SW	29	27	25	22	20	18	16	15	13	12	11	11	11	13	15	18	22	26	29	32	33	33	32	31	22	11	33	22	
W	31	29	27	25	22	20	18	16	14	13	12	12	13	14	16	20	24	29	32	35	35	35	35	33	22	12	35	23	
NW	25	23	21	20	18	16	14	13	11	10	10	10	10	11	12	13	15	18	22	25	27	27	27	26	22	10	27	17	
Group D Walls																													
N	15	13	12	10	9	7	6	6	6	6	6	7	8	10	12	13	15	17	18	19	19	19	18	16	21	6	19	13	
NE	17	15	13	11	10	8	7	8	10	14	17	20	22	23	23	24	24	25	25	24	23	22	20	18	19	7	25	18	
E	19	17	15	13	11	9	8	9	12	17	22	27	30	32	33	33	32	31	30	28	26	24	22	17	8	33	24		
SE	20	17	15	13	11	10	8	8	10	13	17	22	26	29	31	32	32	32	31	30	28	26	24	22	17	8	33	24	
S	19	17	15	13	11	9	8	7	6	6	7	9	12	16	20	24	27	29	29	29	27	26	24	22	19	6	29	23	
SW	28	25	22	19	16	14	12	10	9	8	8	10	12	16	21	27	32	36	38	38	37	34	31	21	8	38	30		
W	31	27	24	21	18	15	13	11	10	9	9	10	11	14	18	24	30	36	40	41	40	38	34	21	9	41	32		
NW	25	22	19	17	14	12	10	9	8	7	7	8	9	10	12	14	18	22	27	31	32	32	30	27	22	7	32	28	
Group E Walls																													
N	12	10	8	7	5	4	3	4	5	6	7	9	11	13	15	17	19	20	21	23	20	18	16	14	20	3	22	19	
NE	13	11	9	7	6	4	5	9	13	20	24	25	25	26	26	26	26	26	25	24	22	19	17	15	16	4	26	22	
E	14	12	10	8	6	5	6	11	18	26	33	36	38	37	36	34	33	32	30	28	25	22	20	17	13	5	38	33	
SE	15	12	10	8	7	5	5	8	12	19	25	31	35	37	37	36	34	33	31	28	26	23	20	17	15	5	37	32	
S	15	12	10	8	7	5	4	3	4	5	9	13	19	24	29	32	34	33	31	29	26	23	20	17	13	3	34	31	
SW	22	18	15	12	10	8	6	5	5	6	7	9	12	18	24	32	38	43	45	44	40	35	30	26	19	5	45	40	
W	25	21	17	14	11	9	7	6	6	6	7	9	11	14	20	27	36	43	49	49	45	40	34	29	20	6	49	43	
NW	20	17	14	11	9	7	6	5	5	5	6	8	10	13	16	20	26	32	37	38	36	32	28	24	20	5	38	33	
Group F Walls																													
N	8	6	5	3	2	1	2	4	6	7	9	11	14	17	19	21	22	23	24	23	20	16	13	11	19	1	23	23	
NE	9	7	5	3	2	1	5	14	23	28	30	29	28	27	27	27	26	24	22	19	16	13	11	11	1	1	30	29	
E	10	7	6	4	3	2	6	17	28	38	44	45	43	39	36	34	32	30	27	24	21	17	15	12	12	2	45	43	
SE	10	7	6	4	3	2	4	10	19	28	36	41	43	42	39	36	34	31	28	25	21	18	15	12	13	2	43	41	
S	10	8	6	4	3	2	1	1	3	7	13	20	27	34	38	39	38	35	31	26	22	18	15	12	16	1	39	38	
SW	15	11	9	6	5	3	2	2	4	5	8	11	17	26	35	44	50	53	52	45	37	28	23	18	18	2	53	48	
W	17	13	10	7	5	4	3	3	4	6	8	11	14	20	28	39	49	57	60	54	43	34	27	21	19	3	60	57	
NW	14	10	8	6	4	3	2	2	3	5	8	10	13	15	21	27	35	42	46	43	35	28	22	18	19	2	46	44	
Group G Walls																													
N	3	2	1	0	-1	2	7	8	9	12	15	18	21	23	24	24	25	26	22	15	11	9	7	5	18	-1	26	27	
NE	3	2	1	0	-1	9	27	36	39	35	30	26	26	27	27	26	25	22	18	14	11	9	7	5	9	-1			

Lampiran 31

COOLING LOAD CALCULATIONS 127

TABLE 6.3 WALL CONSTRUCTION GROUP DESCRIPTION

Group No.	Description of Construction	Weight (lb/ft ²)	U-Value (BTU/h•ft ² •°F)
4-in. Face brick + (brick)			
C	Air space + 4-in. face brick	83	0.358
D	4-in. common brick	90	0.415
C	1-in. insulation or air space + 4-in. common brick	90	0.174–0.301
B	2-in. insulation + 4-in. common brick	88	0.111
B	8-in. common brick	130	0.302
A	Insulation or air space + 8-in. common brick	130	0.154–0.243
4-in. Face brick + (heavyweight concrete)			
C	Air space + 2-in. concrete	94	0.350
B	2-in. insulation + 4-in. concrete	97	0.116
A	Air space or insulation + 8-in. or more concrete	143–190	0.110–0.112
4-in. Face brick + (light or heavyweight concrete block)			
E	4-in. block	62	0.319
D	Air space or insulation + 4-in. block	62	0.153–0.246
D	8-in. block	70	0.274
C	Air space or 1-in. insulation + 6-in. or 8-in. block	73–89	0.221–0.275
B	2-in. insulation + 8-in. block	89	0.096–0.107
4-in. Face brick + (clay tile)			
D	4-in. tile	71	0.381
D	Air space + 4-in. tile	71	0.281
C	Insulation + 4-in. tile	71	0.169
C	8-in. tile	96	0.275
B	Air space or 1-in. insulation + 8-in. tile	96	0.142–0.221
A	2-in. insulation + 8-in. tile	97	0.097
Heavyweight concrete wall + (finish)			
E	4-in. concrete	63	0.585
D	4-in. concrete + 1-in. or 2-in. insulation	63	0.119–0.200
C	2-in. insulation + 4-in. concrete	63	0.119
C	8-in. concrete	109	0.490
B	8-in. concrete + 1-in. or 2-in. insulation	110	0.115–0.187
A	2-in. insulation + 8-in. concrete	110	0.115
B	12-in. concrete	156	0.421
A	12-in. concrete + insulation	156	0.113
Light and heavyweight concrete block + (finish)			
F	4-in. block + air space/insulation	29	0.161–0.263
E	2-in. insulation + 4-in. block	29–37	0.105–0.114
E	8-in. block	47–51	0.294–0.402
D	8-in. block + air space/insulation	41–57	0.149–0.173
Clay tile + (finish)			
F	4-in. tile	39	0.419
F	4-in. tile + air space	39	0.303
E	4-in. tile + 1-in. insulation	39	0.175
D	2-in. insulation + 4-in. tile	40	0.110
D	8-in. tile	63	0.296
C	8-in. tile + air space/1-in. insulation	63	0.151–0.231
B	2-in. insulation + 8-in. tile	63	0.099
Metal curtain wall			
G	With/without air space + 1- to 3-in. insulation	5–6	0.091–0.230
Frame wall			
G	1-in. to 3-in. insulation	16	0.081–0.178

Reprinted with permission from the 1989 ASHRAE Handbook—Fundamentals.

Lampiran 32

128 CHAPTER 6

TABLE 6.4 CLTD CORRECTION FOR LATITUDE AND MONTH APPLIED TO WALLS AND ROOFS, NORTH LATITUDES, F

Lat.	Month	N	NNE NNW	NE NW	ENE WNW	E W	ESE WSW	SE SW	SSE SSW	S	HOR
0	Dec	-3	-5	-5	-5	-2	0	3	6	9	-1
	Jan/Nov	-3	-5	-4	-4	-1	0	2	4	7	-1
	Feb/Oct	-3	-2	-2	-2	-1	-1	0	-1	0	0
	Mar/Sept	-3	0	1	-1	-1	-3	-3	-5	-8	0
	Apr/Aug	5	4	3	0	-2	-5	-6	-8	-8	-2
	May/Jul	10	7	5	0	-3	-7	-8	-9	-8	-4
	Jun	12	9	5	0	-3	-7	-9	-10	-8	-5
8	Dec	-4	-6	-6	-6	-3	0	4	8	12	-5
	Jan/Nov	-3	-5	-6	-5	-2	0	3	6	10	-4
	Feb/Oct	-3	-4	-3	-3	-1	-1	1	2	4	-1
	Mar/Sept	-3	-2	-1	-1	-1	-2	-2	-3	-4	0
	Apr/Aug	2	2	2	0	-1	-4	-5	-7	-7	-1
	May/Jul	7	5	4	0	-2	-5	-7	-9	-7	-2
	Jun	9	6	4	0	-2	-6	-8	-9	-7	-2
16	Dec	-4	-6	-8	-8	-4	-1	4	9	13	-9
	Jan/Nov	-4	-6	-7	-7	-4	-1	4	8	12	-7
	Feb/Oct	-3	-5	-5	-4	-2	0	2	5	7	-4
	Mar/Sept	-3	-3	-2	-2	-1	-1	0	0	0	-1
	Apr/Aug	-1	0	-1	-1	-1	-3	-3	-5	-6	0
	May/Jul	4	3	3	0	-1	-4	-5	-7	-7	0
	Jun	6	4	4	1	-1	-4	-6	-8	0	-7
24	Dec	-5	-7	-9	-10	-7	-3	3	9	13	-13
	Jan/Nov	-4	-6	-8	-9	-6	-3	9	3	13	-11
	Feb/Oct	-4	-5	-6	-6	-3	-1	3	7	10	-7
	Mar/Sept	-3	-4	-3	-3	-1	-1	1	2	4	-3
	Apr/Aug	-2	-1	0	-1	-1	-2	-1	-2	-3	0
	May/Jul	1	2	2	0	0	-3	-3	-5	-6	1
	Jun	3	3	3	1	0	-3	-4	-6	-6	1
32	Dec	-5	-7	-10	-11	-8	-5	2	9	12	-17
	Jan/Nov	-5	-7	-9	-11	-8	-15	-4	2	9	12
	Feb/Oct	-4	-6	-7	-8	-4	-2	4	8	11	-10
	Mar/Sept	-3	-4	-4	-4	-2	-1	3	5	7	-5
	Apr/Aug	-2	-2	-1	-2	0	-1	0	1	1	-1
	May/Jul	1	1	1	0	0	-1	-1	-3	-3	1
	Jun	1	2	2	1	0	-2	-2	-4	-4	2
40	Dec	-6	-8	-10	-13	-10	-7	0	7	10	-21
	Jan/Nov	-5	-7	-10	-12	-9	-6	1	8	11	-19
	Feb/Oct	-5	-7	-8	-9	-6	-3	3	8	12	-14
	Mar/Sept	-4	-5	-5	-6	-3	-1	4	7	10	-8
	Apr/Aug	-2	-3	-2	-2	0	0	2	3	4	-3
	May/Jul	0	0	0	0	0	0	0	0	1	1
	Jun	1	1	1	0	1	0	0	-1	-1	2
48	Dec	-6	-8	-11	-14	-13	-10	-3	2	6	-25
	Jan/Nov	-6	-8	-11	-13	-11	-8	-1	5	8	-24
	Feb/Oct	-5	-7	-10	-11	-8	-5	1	8	11	-18
	Mar/Sept	-4	-6	-6	-7	-4	-1	4	8	11	-11
	Apr/Aug	-3	-3	-3	-3	-1	0	4	6	7	-5
	May/Jul	0	-1	0	0	1	1	3	3	4	0
	Jun	1	1	2	1	2	1	2	2	3	2

Reprinted with permission from the 1989 ASHRAE Handbook—Fundamentals.

Lampiran 33

Chapter 3 External Load Factors

3.35

Table 3.25 Maximum Solar Heat Gain Factor, Btu/(hr · ft²) for Sunlit Glass, North Latitudes

0 Deg										
	N	NNE/NNW	NE/NW	ENE/WNW	E/W	ESE/WSW	SE/SW	SSE/SSW	S	HOR
Jan.	34	34	88	177	234	254	235	182	118	296
Feb.	36	39	132	205	245	247	210	141	67	306
Mar.	38	87	170	223	242	223	170	87	38	303
Apr.	71	134	193	224	221	184	118	38	37	284
May	113	164	203	218	201	154	80	37	37	265
June	129	173	206	212	191	140	66	37	37	255
July	115	164	201	213	195	149	77	38	38	260
Aug.	75	134	187	216	212	175	112	39	38	276
Sep.	40	84	163	213	231	213	163	84	40	293
Oct.	37	40	129	199	236	238	202	135	66	299
Nov.	35	35	88	175	230	250	230	179	117	293
Dec.	34	34	71	164	226	253	240	196	138	288

4 Deg										
	N	NNE/NNW	NE/NW	ENE/WNW	E/W	ESE/WSW	SE/SW	SSE/SSW	S	HOR
Jan.	33	33	79	170	229	252	237	193	141	286
Feb.	35	35	123	199	242	248	215	152	88	301
Mar.	38	77	163	219	242	227	177	96	43	302
Apr.	55	125	189	223	223	190	126	43	38	287
May	93	154	200	220	206	161	89	38	38	272
June	110	164	202	215	196	147	73	38	38	263
July	96	154	197	215	200	156	85	39	38	267
Aug.	59	124	184	215	214	181	120	42	40	279
Sep.	39	75	156	209	231	216	170	93	44	293
Oct.	36	36	120	193	234	239	207	148	86	294
Nov.	34	34	79	168	226	248	232	190	139	284
Dec.	33	33	62	157	221	250	242	206	160	277

8 Deg										
	N	NNE/NNW	NE/NW	ENE/WNW	E/W	ESE/WSW	SE/SW	SSE/SSW	S	HOR
Jan.	32	32	71	163	224	250	242	203	162	275
Feb.	34	34	114	193	239	248	219	165	110	294
Mar.	37	67	156	215	241	230	184	110	55	300
Apr.	44	117	184	221	225	195	134	53	39	289
May	74	146	198	220	209	167	97	39	38	277
June	90	155	200	217	200	141	82	39	39	269
July	77	145	195	215	204	162	93	40	39	272
Aug.	47	117	179	214	216	186	128	51	41	282
Sep.	38	66	149	205	230	219	176	107	56	290
Oct.	35	35	112	187	231	239	211	160	108	288
Nov.	33	33	71	161	220	245	233	200	160	273
Dec.	31	31	55	149	215	246	247	215	179	265

12 Deg										
	N	NNE/NNW	NE/NW	ENE/WNW	E/W	ESE/WSW	SE/SW	SSE/SSW	S	HOR
Jan.	31	31	63	155	217	246	247	212	182	262
Feb.	34	34	105	186	235	248	226	177	133	286
Mar.	36	58	148	210	240	233	190	124	73	297
Apr.	40	108	178	219	227	200	142	64	40	290
May	60	139	194	220	212	173	106	40	40	280
June	75	149	198	217	204	161	90	40	40	274
July	63	139	191	215	207	168	102	41	41	275
Aug.	42	109	174	212	218	191	135	62	142	282
Sep.	37	57	142	201	229	222	182	121	73	287
Oct.	34	34	103	180	227	238	219	172	130	280
Nov.	32	32	63	153	214	241	243	209	179	260
Dec.	30	30	47	141	207	242	251	223	197	250

16 Deg										
	N	NNE/NNW	NE/NW	ENE/WNW	E/W	ESE/WSW	SE/SW	SSE/SSW	S	HOR
Jan.	30	30	55	147	210	244	251	223	199	248
Feb.	33	33	96	180	231	247	233	188	154	275
Mar.	35	53	140	205	239	235	197	138	93	291
Apr.	39	99	172	216	227	204	150	77	45	289
May	52	132	189	218	215	179	115	45	41	282
June	66	142	194	217	207	167	99	41	41	277
July	55	132	187	214	210	174	111	44	42	277
Aug.	41	100	168	209	219	196	143	74	46	282
Sep.	36	50	134	196	227	224	191	134	93	282
Oct.	33	33	95	174	223	237	225	183	150	270
Nov.	30	30	55	145	206	241	247	220	196	246
Dec.	29	29	41	132	198	241	254	233	212	234

20 Deg										
	N	NNE/NNW	NE/NW	ENE/WNW	E/W	ESE/WSW	SE/SW	SSE/SSW	S	HOR
Jan.	29	29	48	138	201	243	253	233	214	232
Feb.	31	31	88	173	226	244	238	201	174	263
Mar.	34	49	132	200	237	236	206	152	115	284
Apr.	38	92	166	213	228	208	158	91	58	287
May	47	123	184	217	217	184	124	54	42	283
June	59	135	189	216	210	173	108	45	42	279
July	48	124	182	213	212	179	119	53	43	278
Aug.	40	91	162	206	220	200	152	88	57	280
Sep.	36	46	127	191	225	225	199	148	114	275
Oct.	32	32	87	167	217	236	231	196	170	258
Nov.	29	29	48	136	197	239	249	229	211	230
Dec.	27	27	35	122	187	238	254	241	226	217

24 Deg										
	N	NNE/NNW	NE/NW	ENE/WNW	E/W	ESE/WSW	SE/SW	SSE/SSW	S	HOR
Jan.	27	27	41	128	190	240	253	241	227	214
Feb.	30	30	80	165	220	244	243	213	192	249
Mar.	34	45	124	195	234	237	214	168	137	275
Apr.	37	88	159	209	228	212	169	107	75	283
May	43	117	178	214	218	190	132	67	46	282
June	55	127	184	214	212	179	117	55	43	279
July	45	116	176	210	213	185	129	65	46	278
Aug.	38	87	156	203	220	204	162	103	72	277
Sep.	35	42	119	185	222	225	206	163	134	266
Oct.	31	31	79	159	211	237	235	207	187	244
Nov.	27	27	42	126	187	236	249	237	224	213
Dec.	26	26	29	112	180	234	247	247	237	199

28 Deg										
	N (Shade)	NNE/NNW	NE/NW	ENE/WNW	E/W	ESE/WSW	SE/SW	SSE/SSW	S	HOR
Jan.	25	25	35	117	183	235	251	247	238	196
Feb.	29	29	72	157	213	244	246	224	207	234
Mar.	33	41	116	189	231	237	221	182	157	265
Apr.	36	84	151	205	228	216	178	124	94	278
May	40	115	172	211	219	195	144	83	58	280
June	51	125	178	211	213	184	128	68	49	278
July	41	114	170	208	215	190	140	80	57	276
Aug.	38	83	149	199	220	207	172	120	91	272
Sep.	34	38	111	179	219	226	213	177	154	256
Oct.	30	30	71	151	204	236	238	217	202	229
Nov.	26	26	35	115	181	232	247	243	235	195
Dec.	24	24	24	99	172	227	248	251	246	179

Lampiran 34

Table 3.18 Shading Coefficients for Glass Without or With Interior Shading by Venetian Blinds or Roller Shades

	Type of Glass	Nominal Thickness Each Light ^a	Solar Trans. ^b	No Interior Shading		Type of Interior Shading				
				$h_o = 4.0$	$h_o = 3.0$	Venetian Blinds		Roller Shades		
						Medium	Light	Opaque		Translucent
								Dark	Light	Light
SINGLE GLASS	Single									
	Clear	3/32 to 1/4	0.87-0.80	1.00	1.00					
	Clear	1/4 to 1/2	0.80-0.71	0.94	0.95					
	Clear	3/8	0.72	0.90	0.92	0.64	0.55	0.59	0.25	0.39
	Clear	1/2	0.67	0.87	0.88					
	Clear Pattern	1/8 to 9/32	0.87-0.79	0.83	0.85					
	Heat Absorbing Pattern	1/8		0.83	0.85					
	Heat Absorbing ^c	3/16 to 1/4	0.46	0.69	0.73					
	Heat Absorbing Pattern	3/16 to 1/4		0.69	0.73	0.57	0.53	0.45	0.30	0.36
	Tinted	1/8 to 7/32	0.59-0.45	0.69	0.73					
	Heat Absorbing or Pattern		0.44-0.30	0.60	0.64	0.54	0.52	0.40	0.28	0.32
	Heat Absorbing ^c	3/8	0.34	0.60	0.64					
	Heat Absorbing or Pattern	1/2	0.44-0.30	0.53	0.58	0.42	0.40	0.36	0.28	0.31
	Reflective Coated Glass			0.30		0.25	0.23			
INSULATING GLASS				0.40		0.33	0.29			
				0.50		0.42	0.38			
				0.60		0.50	0.44			
	Double ^d									
	Clear Out	3/32, 1/8	0.71 ^a	0.88	0.88	0.57	0.51	0.60	0.25	0.37
	Clear In									
	Clear Out	1/4	0.61 ^a	0.81	0.82					
	Clear In									
	Heat Absorbing Out	1/4	0.36 ^a	0.55	0.58					
	Clear In					0.39	0.36	0.40	0.22	0.30
	Reflective Coated Glass			0.20		0.19	0.18			
				0.30		0.27	0.26			
				0.40		0.34	0.33			
	Triple									
	Clear	1/4		0.71						
	Clear	1/8		0.80						

^a Refer to manufacturer's literature for values.^b For vertical blinds with opaque white and beige louvers in the tightly closed position, SC is 0.25 and 0.29 when used with glass of 0.71 to 0.80 transmittance.^c Refers to grey, bronze and green tinted heat-absorbing glass.^d Refers to factory-fabricated units with 3/16, 1/4 or 1/2 in. air space or to prime windows plus storm windows.

Lampiran 35

TABLE 6.15 HEAT GAIN FROM EQUIPMENT

Appliance	Size	Recommended Rate of Heat Gain, BTU/hr			
		Without Hood			With Hood
		Sensible	Latent	Total	Sensible
Restaurant, electric blender, per quart of capacity	1 to 4 qt	1000	520	1520	480
Coffee brewer	12 cups/2 brnrs	3750	1910	5660	1810
Coffee heater, per warming burner	1 to 2 brnrs	230	110	340	110
Display case (refrigerated), per ft ³ of interior	6 to 67 ft ³	62	0	62	0
Hot plate (high-speed double burner)		7810	5430	13,240	6240
Ice maker (large)	220 lb/day	9320	0	9320	0
Microwave oven (heavy-duty commercial)	0.7 ft ³	8970	0	8970	0
Toaster (large pop-up)	10 slice	9590	8500	18,080	5800

Appliance	Size	Recommended Rate of Heat Gain, BTU/hr			
Computer Devices					
Communication/transmission			5600–9600		
Disk drives/mass storage			3400–22,400		
Microcomputer/word processor	16–640 kbytes		300–1800		
Minicomputer			7500–15,000		
Printer (laser)	8 pages/min		1000		
Printer (line, high-speed)	5000 or more pages/min		2500–13,000		
Tape drives			3500–15,000		
Terminal			270–600		
Copiers/Typesetters					
Blue print			3900–42,700		
Copiers (large)	30–67 copies/min		1700–6600		
Copiers	6–30 copies/min		460–1700		
Miscellaneous					
Cash register			160		
Cold food/beverage			1960–3280		
Coffeemaker	10 cup	sensible	3580		
		latent	1540		
Microwave oven	1 ft ³		1360		
Paper shredder			680–8250		
Water cooler	8 gal/hr		6000		

Abridged with permission from the 1993 ASHRAE Volume—Fundamentals.

Lampiran 36

Table 3.23 Cooling Load Temperature Difference for Conduction Through Glass and Conduction Through Doors

Solar Time, hr																							
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
CLTD, F																							
1	0	-1	-2	-2	-2	0	2	4	7	9	12	13	14	14	13	12	10	8	6	4	3	2	

Lampiran 37

Table 3.14A Overall Coefficients of Heat Transmission (U-Factor) of Windows and Skylights, Btu/(hr·ft²·F)

Description	Exterior Vertical Panels				Exterior Horizontal Panels (Skylights)	
	Summer**		Winter*		Summer ^j	Winter ⁱ
	No Indoor Shade	Indoor Shade***	No Indoor Shade	Indoor Shade***		
Flat Glass ^b						
Single Glass	1.04	0.81	1.10	0.83	0.83	1.23
Insulating Glass, Double ^c						
3/16 in. air space ^d	0.65	0.58	0.62	0.52	0.57	0.70
1/4 in. air space ^d	0.61	0.55	0.58	0.48	0.54	0.65
1/2 in. air space ^e	0.56	0.52	0.49	0.42	0.49	0.59
1/2 in. air space, low emittance coating ^f						
e = 0.20	0.38	0.37	0.32	0.30	0.36	0.48
e = 0.40	0.45	0.44	0.38	0.35	0.42	0.52
e = 0.60	0.51	0.48	0.43	0.38	0.46	0.56
Insulating Glass, Triple ^c						
1/4 in. air space ^d	0.44	0.40	0.39	0.31		
1/2 in. air space ^g	0.39	0.36	0.31	0.26		
Storm Windows						
1 in. to 4 in. air spaces ^d	0.50	0.48	0.50	0.42		
Plastic Bubbles ^k						
Single					0.80	1.15
Double					0.46	0.70

Lampiran 38


3.38

Cooling and Heating Load Calculation Manual

Table 3.27 Cooling Load Factors for Glass without Interior Shading, North Latitudes

Fenestration Facing	Room Construction	Solar Time, hr.																							
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
N (Shaded)	L	0.17	0.14	0.11	0.09	0.08	0.33	0.42	0.48	0.56	0.63	0.71	0.76	0.80	0.82	0.82	0.79	0.79	0.84	0.61	0.48	0.38	0.31	0.25	0.20
	M	0.23	0.20	0.18	0.16	0.14	0.34	0.41	0.46	0.53	0.59	0.65	0.70	0.74	0.75	0.76	0.74	0.75	0.79	0.61	0.50	0.42	0.36	0.31	0.27
	H	0.25	0.23	0.21	0.20	0.19	0.38	0.45	0.49	0.55	0.60	0.65	0.69	0.72	0.72	0.72	0.70	0.70	0.75	0.57	0.46	0.39	0.34	0.31	0.28
NNE	L	0.06	0.05	0.04	0.03	0.03	0.26	0.43	0.47	0.44	0.41	0.40	0.39	0.39	0.38	0.36	0.33	0.30	0.26	0.20	0.16	0.13	0.10	0.08	0.07
	M	0.09	0.08	0.07	0.06	0.06	0.24	0.38	0.42	0.39	0.37	0.37	0.36	0.36	0.36	0.34	0.33	0.30	0.27	0.22	0.18	0.16	0.14	0.12	0.10
	H	0.11	0.10	0.09	0.09	0.08	0.26	0.39	0.42	0.39	0.36	0.35	0.34	0.34	0.33	0.32	0.31	0.28	0.25	0.21	0.18	0.16	0.14	0.13	0.12
NE	L	0.04	0.04	0.03	0.02	0.02	0.23	0.41	0.51	0.51	0.45	0.39	0.36	0.33	0.31	0.28	0.26	0.23	0.19	0.15	0.12	0.10	0.08	0.06	0.05
	M	0.07	0.06	0.06	0.05	0.04	0.21	0.36	0.44	0.45	0.40	0.36	0.33	0.31	0.30	0.28	0.26	0.24	0.21	0.17	0.15	0.13	0.11	0.09	0.08
	H	0.09	0.08	0.08	0.07	0.07	0.23	0.37	0.44	0.44	0.39	0.34	0.31	0.29	0.27	0.26	0.24	0.22	0.20	0.17	0.14	0.13	0.12	0.11	0.10
ENE	L	0.04	0.03	0.03	0.02	0.02	0.21	0.40	0.52	0.57	0.53	0.45	0.39	0.34	0.31	0.28	0.25	0.22	0.18	0.14	0.12	0.09	0.08	0.06	0.05
	M	0.07	0.06	0.05	0.05	0.04	0.20	0.35	0.45	0.49	0.47	0.41	0.36	0.33	0.30	0.28	0.26	0.23	0.20	0.17	0.14	0.12	0.11	0.09	0.08
	H	0.09	0.08	0.08	0.07	0.07	0.22	0.36	0.46	0.49	0.45	0.38	0.33	0.30	0.27	0.25	0.23	0.21	0.19	0.16	0.14	0.13	0.12	0.11	0.10
E	L	0.04	0.03	0.03	0.02	0.02	0.19	0.37	0.51	0.57	0.57	0.50	0.42	0.37	0.32	0.29	0.25	0.22	0.19	0.15	0.12	0.10	0.08	0.06	0.05
	M	0.07	0.06	0.06	0.05	0.05	0.18	0.33	0.44	0.50	0.51	0.46	0.39	0.35	0.31	0.29	0.26	0.23	0.21	0.17	0.15	0.13	0.11	0.10	0.08
	H	0.09	0.09	0.08	0.08	0.07	0.20	0.34	0.45	0.49	0.49	0.43	0.36	0.32	0.29	0.26	0.24	0.22	0.19	0.17	0.15	0.13	0.12	0.11	0.10
ESE	L	0.05	0.04	0.03	0.03	0.02	0.17	0.34	0.49	0.58	0.61	0.57	0.48	0.41	0.36	0.32	0.28	0.24	0.20	0.16	0.13	0.10	0.09	0.07	0.06
	M	0.08	0.07	0.06	0.05	0.05	0.16	0.31	0.43	0.51	0.54	0.51	0.44	0.39	0.35	0.32	0.29	0.26	0.22	0.19	0.16	0.14	0.12	0.11	0.09
	H	0.10	0.09	0.09	0.08	0.08	0.19	0.32	0.43	0.50	0.52	0.49	0.41	0.36	0.32	0.29	0.26	0.24	0.21	0.18	0.16	0.14	0.13	0.12	0.11
SE	L	0.05	0.04	0.04	0.03	0.03	0.13	0.28	0.43	0.55	0.62	0.63	0.57	0.48	0.42	0.37	0.33	0.28	0.24	0.19	0.15	0.12	0.10	0.08	0.07
	M	0.09	0.08	0.07	0.06	0.05	0.14	0.26	0.38	0.48	0.54	0.56	0.51	0.45	0.40	0.36	0.33	0.29	0.25	0.21	0.18	0.16	0.14	0.12	0.10
	H	0.11	0.10	0.10	0.09	0.08	0.17	0.28	0.40	0.49	0.53	0.53	0.48	0.41	0.36	0.33	0.30	0.27	0.24	0.20	0.18	0.16	0.14	0.13	0.12
SSE	L	0.07	0.05	0.04	0.04	0.03	0.06	0.15	0.29	0.43	0.55	0.63	0.64	0.60	0.52	0.45	0.40	0.35	0.29	0.23	0.18	0.15	0.12	0.10	0.08
	M	0.11	0.09	0.08	0.07	0.06	0.08	0.16	0.26	0.38	0.48	0.55	0.57	0.54	0.48	0.43	0.39	0.35	0.30	0.25	0.21	0.18	0.16	0.14	0.12
	H	0.12	0.11	0.11	0.10	0.09	0.12	0.19	0.29	0.40	0.49	0.54	0.55	0.51	0.44	0.39	0.35	0.31	0.27	0.23	0.20	0.18	0.16	0.15	0.13
S	L	0.08	0.07	0.05	0.04	0.04	0.06	0.09	0.14	0.22	0.34	0.48	0.59	0.65	0.65	0.59	0.50	0.43	0.36	0.28	0.22	0.18	0.15	0.12	0.10
	M	0.12	0.11	0.09	0.08	0.07	0.08	0.11	0.14	0.21	0.31	0.42	0.52	0.57	0.58	0.53	0.47	0.41	0.35	0.29	0.25	0.21	0.18	0.16	0.14
	H	0.13	0.12	0.12	0.11	0.10	0.11	0.14	0.17	0.24	0.33	0.43	0.51	0.56	0.55	0.50	0.43	0.37	0.32	0.26	0.22	0.20	0.18	0.16	0.15
SSW	L	0.10	0.08	0.07	0.06	0.05	0.06	0.09	0.11	0.15	0.19	0.27	0.39	0.52	0.62	0.67	0.65	0.58	0.46	0.36	0.28	0.23	0.19	0.15	0.12
	M	0.15	0.14	0.12	0.10	0.09	0.10	0.12	0.13	0.15	0.18	0.25	0.35	0.46	0.55	0.59	0.59	0.53	0.44	0.35	0.30	0.25	0.22	0.19	0.16
	H	0.15	0.14	0.13	0.12	0.11	0.12	0.14	0.16	0.18	0.21	0.27	0.37	0.46	0.53	0.57	0.55	0.49	0.40	0.32	0.26	0.23	0.20	0.18	0.16
SW	L	0.12	0.10	0.08	0.06	0.05	0.06	0.08	0.10	0.12	0.14	0.16	0.24	0.36	0.49	0.60	0.66	0.66	0.58	0.43	0.33	0.27	0.22	0.18	0.14
	M	0.15	0.13	0.12	0.10	0.09	0.09	0.10	0.11	0.12	0.13	0.14	0.17	0.24	0.35	0.46	0.54	0.58	0.53	0.41	0.33	0.28	0.24	0.21	0.18
	H	0.15	0.14	0.13	0.12	0.11	0.12	0.13	0.14	0.16	0.17	0.19	0.25	0.34	0.44	0.52	0.56	0.56	0.49	0.37	0.30	0.25	0.21	0.19	0.17
WSW	L	0.12	0.10	0.08	0.07	0.05	0.06	0.07	0.09	0.10	0.12	0.13	0.17	0.26	0.40	0.52	0.62	0.66	0.61	0.44	0.34	0.27	0.22	0.18	0.15
	M	0.15	0.13	0.12	0.10	0.09	0.09	0.10	0.11	0.12	0.13	0.14	0.17	0.24	0.35	0.46	0.54	0.58	0.55	0.42	0.34	0.28	0.24	0.21	0.18
	H	0.15	0.14	0.13	0.12	0.11	0.11	0.12	0.13	0.14	0.15	0.16	0.19	0.26	0.36	0.46	0.53	0.56	0.51	0.38	0.30	0.25	0.21	0.19	0.17
W	L	0.12	0.10	0.08	0.06	0.05	0.06	0.07	0.08	0.10	0.11	0.12	0.14	0.20	0.32	0.45	0.57	0.64	0.61	0.44	0.34	0.27	0.22	0.18	0.14
	M	0.15	0.13	0.11	0.10	0.09	0.09	0.09	0.10	0.11	0.12	0.13	0.14	0.19	0.29	0.40	0.50	0.56	0.55	0.41	0.33	0.27	0.23	0.20	0.17
	H	0.14	0.13	0.12	0.11	0.10	0.11	0.12	0.13	0.14	0.14	0.15	0.16	0.21	0.30	0.40	0.49	0.54	0.52	0.38	0.30	0.24	0.21	0.18	0.16
WNW	L	0.12	0.10	0.08	0.06	0.05	0.06	0.07	0.09	0.10	0.12	0.13	0.15	0.17	0.26	0.40	0.53	0.63	0.62	0.44	0.34	0.27	0.22	0.18	0.14
	M	0.15	0.13	0.11	0.10	0.09	0.09	0.10	0.11	0.12	0.13	0.14	0.15	0.17	0.24	0.35	0.47	0.55	0.55	0.41	0.33	0.27	0.23	0.20	0.17
	H	0.14	0.13	0.12	0.11	0.10	0.11	0.12	0.13	0.14	0.15	0.16	0.17	0.18	0.25	0.36	0.46	0.53	0.52	0.38	0.30	0.24	0.20	0.18	0.16
NW	L	0.11	0.09	0.08	0.06	0.05	0.06	0.08	0.10	0.12	0.14	0.16	0.17	0.19	0.23	0.33	0.47	0.59	0.60	0.42	0.33	0.26	0.21	0.17	0.14
	M	0.14	0.12	0.11	0.09	0.08	0.09	0.10	0.11	0.13	0.15	0.16	0.17	0.18	0.21	0.30	0.42	0.51	0.54	0.39	0.32	0.26	0.22	0.19	0.16
	H	0.14	0.12	0.11	0.10	0.10	0.10	0.12	0.13	0.15	0.16	0.18	0.18	0.19	0.22	0.30	0.41	0.50	0.51	0.36	0.29	0.23	0.20	0.17	0.15
NNW	L	0.12	0.09	0.08	0.06	0.05	0.07	0.11	0.14	0.18	0.22	0.25	0.27	0.29	0.30	0.33	0.44	0.57	0.62	0.44	0.33	0.26	0.21	0.17	0.14
	M	0.15	0.13	0.11	0.10	0.09	0.10	0.12	0.15	0.18	0.21	0.23	0.26	0.27	0.28	0.31	0.39	0.51	0.56	0.41	0.33	0.27	0.23	0.20	0.17
	H	0.14	0.13	0.12	0.11	0.10	0.12	0.15	0.17	0.20	0.23	0.25	0.26	0.28	0.28	0.31	0.38	0.49	0.53	0.38	0.30	0.25	0.21	0.18	0.16
HOR.	L	0.11	0.09	0.07	0.06	0.05	0.07	0.14	0.24	0.36	0.48	0.58	0.66	0.72	0.74	0.73	0.67	0.59	0.47	0.37	0.29	0.24	0.19	0.16	0.13
	M	0.16	0.14	0.12	0.11	0.09	0.11																		

Lampiran 39



Lampiran 40

