


DAFTAR PUSTAKA

- Aini, Zulfatr, & Mar'i, Aqil, 2021, *Desain Single Tuned Filter Terhadap Harmonisa Pada Transformator Distribusi*. Al-Mujahadah Press, Riau.
- Akagi, Hirofumi., Watanabe, E. H., & Aredes. M., 2007, *Instantaneous Power Theory and Applications to Power Conditioning*. IEEE Press, New York.
- Arrillaga, J., & Watson, N. R., 2003. *Power System Harmonics*. John Wiley & Sons, Inggris.
- Astrom, K. J., 2002. *Control System Design*. Departement of Mechanical & Environmental Engineering University of California, Santa Barbara.
- Astrom, K. J. & Marry, R. M., 2009. *Feedback System: Introduction for Scientists and Engineers*. Princeton University Press, Oxford.
- Benysek, Grzegor., 2012, *Power Theories for Improved Power Quality*. Springer, London.
- Dhinata, I. S., Pemayun, A. M., & Manuaba. I. G., 2021. Pengaruh Filter Aktif Dengan Pengaturan Daya Reaktif Terhadap Efisiensi Trafo Berbasis *Simulink*. *Jurnal SPEKRUM*. 8(4), 147-153
- Duarsana, I. N., Rinas, I. W., & Wijaya, I. W. A., 2021 Analisa Unjuk Kerja Motor Induksi 3 Phasa Terhadap Pengaruh Harmonisa (THD) Dengan Penambahan Filter Aktif Menggunakan Matlab. *Jurnal SPEKRUM*. 8(1), 123-128
- Dugan, R. C., et al., 2002. *Electrical Power System Quality*. 2nd ed. McGraw Hill Professional, New York.
- Grady, Mack., 2012. *Understanding Power System Harmonics*. Dept. of Electrical & Computer Engineering University of Texas, Amerika Serikat.
- IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems. (2014). IEEE Std 519-2014 (Revision of IEEE Std 519-1992). <https://doi.org/10.1109/IEEESTD.2014.6826459>.
- Kamakshaiah, S., & Kamaraju, V., 2011. *HVDC Transmission*. McGraw Hill, New Delhi.
- Kusko, A., & Thompson, M. T., 2007. *Power Quality in Electrical Systems*. McGraw Hill, New York.


- Martana, I. K., Wijaya, I. W., & Suartika, I. M., 2023. Pengaruh Fikter Katif Terhadap Losses Transformator di Fakultas Teknik Udayana Bukit Jimbaran Dengan Fuzzy Logic Controller Menggunakan *Simulink*. *Jurnal SPEKRUM*. 10(1), 87-96.
- Medium.com. (2021, 15 Februari). Mendesain Teknik “Relay-Feedback PID Auto-Tuning” di Python. Diakses pada 7 November 2024, dari <https://utomorezadwi.medium.com/mendesain-teknik-relay-feedback-pid-auto-tuning-di-python-dedcd99af2d9>.
- Odinanto, T., Winardi, S., & Saputra, K. H., 2013. Perancangan Filter Aktif 3 Fasa Menggunakan Kontrol Propotional Integral Derivative (PID) untuk Mereduksi Harmonisa Pada Sistem Tenaga Listrik. *Jurnal ITATS*
- Ogata, Katsuhiko., 2010. *Modern Control Engineering*. 5th ed. Prentice Hall, London.
- Rosa, Francisco, C. D. L., 2006. *Harmonic and Power System*. 1st ed. CRC Press Boca Raton, Amerika Serikat.
- Saputra, G. A., Rinas, I. W., & Suartika, I. M., 2019. Studi Analisis Pengaruh Filter Aktif Berbasis Fuzzy Logic Controller Untuk Mereduksi Harmonisa Akibat Beban Non-Linier. *Jurnal SPEKTRU*. 6(2), 24-31.
- Scheidiger, Michael., 2013. *Power System Harmonic Analysis of High Power Variable Speed Drives*. Royal Institute of Technology. Stockholm, Sweden.
- Setiawan, Iwan., 2008. *Kontrol PID untuk Proses Industri*. PT Elex Media Komputindo, Surabaya.
- Sianipar, R. H., 2015. *Rangkaian Listrik*. Rekayasa Sains, Bandung.
- Sudirman, S., 2012. *Analisis Rangkaian Listrik. Jilid 2*. Depublik, Bandung.
- Yudha, A. A., Partha, C. G., & Sukerayasa, I. W., 2023. Simulasi Penggunaan Filter Aktif Shunt dengan Kontrol PI untuk Meredam Total Harmonic Distrotion (THD) Pada Gedung DH Teknik Elektri Universitas Udayana. *Jurnal SPEKRUM*. 10(4), 143-151

LAMPIRAN

Lampiran 1 Setting parameter sumber 3 fasa



Lampiran 2 Setting parameter DC link kapasitor



Lampiran 3 Setting parameter alat ukur

Block Parameters: Three-Phase V-I Measurement

Three-Phase VI Measurement (mask) (link)

Ideal three-phase voltage and current measurements.

The block can output the voltages and currents in per unit values or in volts and amperes.

Parameters

Voltage measurement

Use a label

Signal label (use a From block to collect this signal)

Voltages in pu, based on peak value of nominal phase-to-ground voltage

Current measurement

Use a label

Signal label (use a From block to collect this signal)

Currents in pu

OK Cancel Help Apply

Lampiran 4 Setting parameter *universal bridge rectifier 3 phase*

Block Parameters: Beban non-linear

Universal Bridge (mask) (link)

This block implement a bridge of selected power electronics devices. Series RC snubber circuits are connected in parallel with each switch device. Press Help for suggested snubber values when the model is discretized. For most applications the internal inductance L_{on} of diodes and thyristors should be set to zero

Parameters

Number of bridge arms:

Snubber resistance R_s (Ohms)

Snubber capacitance C_s (F)

Power Electronic device


Ron (Ohms)

Lon (H)


Forward voltage V_f (V)

OK Cancel Help Apply


Lampiran 5 setting parameter VSI



Lampiran 6 setting parameter LF



Lampiran 7 Setting parameter PID



Block Parameters: PID Controller

PID 1dof (mask) (link)

This block implements continuous- and discrete-time PID control algorithms and includes advanced features such as anti-windup, external reset, and signal tracking. You can tune the PID gains automatically using the 'Tune...' button (requires Simulink Control Design).

Controller: PID Form: Parallel

Time domain:

Continuous-time
 Discrete-time

Discrete-time settings

Sample time (-1 for inherited): -1

Compensator formula

$$P + I \frac{1}{s} + D \frac{N}{1 + N \frac{1}{s}}$$

Main Initialization Saturation Data Types State Attributes

Controller parameters

Source: internal


Proportional (P): 0.0258

Integral (I): 3.97 Use I*Ts (optimal for codegen)

Derivative (D): 4.192e-5 4.192e-05

OK Cancel Help Apply

Lampiran 8 Setting Parameter FFT



The image shows the 'FFT Analyzer' software interface. At the top, there is a title bar with a small icon and the text 'FFT Analyzer', and a 'Help' button below it. The main area contains several configuration options:

- Structure with time:** A dropdown menu set to 'ScopeData1' and an 'update' button.
- Signal:** A dropdown menu set to 'unnamed (input 1)'.
- Dimension:** A dropdown menu set to '1'.
- Start time (s):** A text input field containing '0'.
- Number of cycles:** A text input field containing '1'.
- Zoom on:** A dropdown menu set to 'Signal'.
- Fundamental frequency (Hz):** A text input field containing '50'.
- Max frequency (Hz):** A text input field containing '2550'.
- Max THD frequency:** A dropdown menu set to 'Nyquist frequency'.
- Display style:** A dropdown menu set to 'Bar (relative to fundamental)'.
- Base value:** A text input field containing '1.0'.
- Frequency axis:** A dropdown menu set to 'Harmonic order'.

At the bottom center, there is a 'Compute FFT' button.